

DOCUMENT 00 0491  
ADDENDUM NO. 3

DATE: February 11, 2010  
PROJECT NAME: Greene County Medical Center AHU Replacement

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated January 22, 2010 with which it conflicts.



ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM.  
FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

A. DRAWINGS

1. Sheet M4.01 – MECHANICAL SCHEDULES & SYMBOLS

- a. **CHANGE** note 4 under Air Handling Unit Schedule to read “All motors shall be belt drive.”

Prepared By: Shive-Hattery, Inc.

	I hereby certify that the portion of this technical submission described below was prepared by me or under my direct supervision and responsible charge. I am a duly Registered Architect under the laws of the State of Iowa.	
	Signature: <u></u>	Date: <u>2/11/10</u>
	Name: <u>James E. Moore, AIA</u>	
	Registration Expires: <u>6/30/2011</u>	Date Issued: <u>4/28/08</u>
	Pages, Sheets, or Divisions covered by this seal: <u>This Addendum.</u>	

END OF DOCUMENT 00 0491