

ADDENDUM 2

to the
PROJECT MANUAL
AND DRAWINGS

for

**Verdigre Public Schools
Elementary School HVAC Improvements**

CWPA Project No. 11509

CARLSON WEST POVONDRA ARCHITECTS
5060 Dodge Street, Omaha, Nebraska 68132-2966

Phone 402-551-1500

Fax 402-551-9488

May 26, 2009

Notice to Bidders

- A. The Contract Documents for the above referenced project are hereby amended as follows:

Project Drawings

Item No. 1 Sheet E0.0 - One Line Diagram

- A. Revise key note 7 to read as follow: " 2 sets of 4-#350's, #1G, 3 ½" conduit."
B. Revise key note 8 to read as follow: "2 sets of 4-#350's, 3 ½" conduit.

Clarification - EMT is **NOT** acceptable for use as exterior exposed conduit under the eave; rigid steel shall be used as indicated in the Contract Documents.

END OF ADDENDUM 2