

Addendum 2



300 East Locust, Ste. 313, Des Moines, Iowa 50309 (515) 243-0569

March 9, 2010

West Hancock High School Phase 2

Alvine No. 2009 0801

Bid Date: March 15, 2010

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein. Specifications and drawings shall be considered modified or revised as hereinafter described. Revisions to the drawings are referenced by the drawing number.

Changes to the Project Manual

Mechanical Specification Items:

2MS1. Section 15940 – HVAC Instrumentation and Control

1. Page 15940-2, Paragraph 1.3: Add the following:

“D. “New control system shall provide a single interface between the existing control system in the adjacent elementary school (Siemens Talon) and the high school.”

Changes to Drawings

Mechanical Drawing Items:

2MD1. Sheet M150 – First Floor – Area A New Piping

1. Add “Flag Note 2” to the fintube radiation in Men’s Toilet and Women’s Toilet 117.

END

AWL/mkm