

DOCUMENT 00 0495
ADDENDUM NO. 5

DATE: August 12, 2010

PROJECT NAME: GREATER REGIONAL MEDICAL CENTER SURGERY CENTER ADDITION, BIRTHING & PATIENT CARE RENOVATIONS

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated July 12, 2010 and Addendum #1 dated July 23, 2010, Addendum #2 dated July 30, 2010, Addendum #3 dated August 4, 2010, and Addendum #5 dated August 11, 2010 with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM.
FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

A. SPECIFICATIONS


1. Section 26 2726 Outlet Boxes and Wiring Devices
 - a. **CHANGE** Paragraph 1.3.A to read as follows:
 - 1) All duplex receptacles within the main hospital and addition shall be hospital grade. Receptacles in the MAP building, mechanical rooms, and penthouses shall be specification grade.
2. Section 27 3106 Category 6 Voice and Data Communications Systems
 - a. **CHANGE** Telephone Room G27 to Telephone Room G74 in paragraph 1.1.A.7.

B. DRAWINGS

1. Sheet E4.03 PARTIAL PLANS AND NOTES:
 - a. **CLARIFICATION:** All tel/data cabling on the ground floor of the MAP building shall be routed to the main telcom room on the ground floor (approximately 250 feet from remodel space).
 - b. **CLARIFICATION:** All tel/data cabling on the ground floor of the MAP building shall be routed to the relocated data rack shown at the north side of the remodel area.
2. Sheet E5.06 EQUIPMENT CONNECTION SCHEDULE, FIXTURE TYPE & SYMBOL LIST:
 - a. **CLARIFICATION:** All data outlet types on the first floor shall have horizontal cabling routed to Telecom Room 1007A.
 - b. **CLARIFICATION:** Access control and CCTV equipment is Owner provided through Security Equipment, Inc. (SEi). Contractor shall provide 120V connections to power supplies and rough-in for devices as indicated. The equipment supplier will install devices, cabling, and make cabling connections.

DOCUMENT 00 0495
ADDENDUM NO. 5

Prepared By: Shive-Hattery, Inc.

	I hereby certify that the portion of this technical submission described below was prepared by me or under my direct supervision and responsible charge. I am a duly Registered Architect under the laws of the State of Iowa.
	Signature: <u><i>David P. Hofmann</i></u> Date: <u>8/12/2010</u>
	Name: <u>David P. Hofmann</u>
	Registration Expires: <u>6/30/12</u> Date Issued: April 6, 2004
	Pages, Sheets, or Divisions covered by this seal: <u>This document.</u>

END OF DOCUMENT 00 0495